

14 March, 2024

Addendum 3

Martin and Carteret County Salt Sheds

Martin SCO #: 21-23599-01A

Carteret SCO #: 21-23601-01-A

The following addendum shall supersede previous information and does hereby become part of the contract documents.

- Clarification, Roof truss design: Live Load 20 psf, Dead Load 10 psf. See also G-1.

End of Addendum 3