

03 March 2026

Addendum 3

Beaufort EMS

Beaufort, NC

The following addendum shall supersede previous information and does hereby become part of the contract documents.

- Windows W1, W2, W3 to be Kawneer I.R. 501T, 2-3/4" x 5" impact resistant storefront frames with 1-5/16" insulated glazing (exterior 1/4" low E solar grey with 1/2" spacer and 9/16" SGP laminate interior).
Note: glazing for W-1 to be spandrel black glass. Window W-4 can be fire rated hollow metal at contractors option
- Exterior Storefront doors and frames 101A and 116A to be Kawneer I.R. 350 impact rated storefront door with 9/16" laminate S.G.P. with continuous hinge, standard MF lock and ADA threshold by door manufacturer and not part of the hardware allowance. Closer will be part of the hardware allowance. Side Lites to be I.R. 501T similar to W-2 and W-3.
- Equal products by Spec-Brik will be acceptable.
- Up to 6 Conex Boxes can be staged on nearby Jarret Bay property. Coordinate exact location with Owner.
- All solid surfaces to be Wilsonart, Level (2).
- Equal roofing products listed below will be acceptable.
 - Construction Metal Products
 - Metal Roofing Systems
 - R.E. Bengel

End of Addendum 3